

ADDENDUM NO. 1

Camden Greenway Project (Sweet Gum Trail) February 2017

Prepared by:

Shawn Putnam
City of Camden
P.O. Box 7002
Camden, SC 29021

DATE OF ISSUE: FEBRUARY, 27, 2017

TO: ALL BIDDERS OF RECORD

This addendum modifies the Contract Documents only in the manner and to the extent stated herein and shown on any accompanying drawings and will become a part of the Contract Documents. Except as specified or otherwise indicated by this addendum, all work shall be in accordance with the basic requirements of the Contract Documents.

Clarifications:

1. The bid opening shall be March 10 at 3:00 PM in the Training Room at Camden City Hall, located at 1000 Lyttleton Street, Camden, SC.
2. The plans call for two sections of 24 inch Reinforced Concrete Pipe to be installed. The first section is marked on Plan Sheets 10 and 14. The second section is marked on Plan Sheets 11 and 15.
3. Disregard the specifications for HDPE located in section 334100 of the Specifications document. Sections of pipe to be installed shall be Reinforced Concrete Pipe as shown on the plans.
4. Asphalt should be installed at a minimum required level to accommodate bicycle and pedestrian traffic, as well as light maintenance truck traffic. Sections D, E, F, and G of Section 3.5 – Compaction on page 321216-4 of the Specifications should not be compromised.
5. On page 1 of the request for bid, item #3 listed under “Provide with the submittal” should read “Bid bond in at least the amount of bid plus five (5) percent” instead of “Performance bond in at least the amount of bid plus five (5) percent.”

End of Addendum No. 1